

CWPVC-9

SEPTEMBER, 2020

	SIZE	O.D.	I.D.	MIN. WALL	WEIGHT PER 100'	FEET PER PALLET	PALLETS PER T.L.	PART NO.
SDR-21 RECLAIMED WATER PIPE 200 PSI PVC1120 ASTM D2241	¾"	1.050	.930	.060	12.12	6600	40	57030
	1	1.315	1.189	.063	16.17	5400	32	57045
	1¼	1.660	1.502	.079	25.60	4000	32	57055
	1½	1.900	1.720	.090	33.32	3600	28	57070
	2	2.375	2.149	.113	52.32	2800	24	57085
	2½	2.875	2.601	.137	76.54	2240	20	57100
	3	3.500	3.166	.167	113.72	1500	20	57110
	4	4.500	4.072	.214	187.92	580	28	57120
	6	6.625	5.993	.316	408.24	400	20	57130

SDR-13.5 RECLAIMED WATER PIPE 315 PSI PVC1120 ASTM D2241	½"	.840	.716	.062	9.81	8400	44	57015
	2	2.375	2.023	.176	78.80	2800	24	57425
	2½	2.875	2.449	.213	113.50	2240	20	57435
	3	3.500	2.982	.259	170.70	1500	20	57445
	4	4.500	3.834	.333	281.80	580	28	57455

SCH-40 RECLAIMED WATER PIPE PVC1120 ASTM D1785	½"	.840	.622	.109	16.25	8400	44	57215
	¾"	1.050	.824	.113	21.67	6600	40	57230
	1	1.315	1.049	.133	32.14	5400	32	57245
	1¼	1.660	1.380	.140	43.58	4000	32	57255
	1½	1.900	1.610	.145	52.05	3600	28	57270
	2	2.375	2.067	.154	70.00	2800	24	57285
	2½	2.875	2.469	.203	111.03	2240	20	57300
	3	3.500	3.068	.216	145.43	1500	20	57310
	4	4.500	4.026	.237	207.06	580	28	57320
	6	6.625	6.065	.280	364.89	400	20	57330
	8	8.625	7.961	.322	549.21	280	16	57340
	10**	10.750	10.020	.365	775.36	160	16	57350
12**	12.750	11.938	.406	1025.36	120	12	57360	

** NON-STOCK ITEM

SDR-21 GASKET JOINT RECLAIMED WATER PIPE 200 PSI PVC1120 ASTM D2241	3"	3.500	3.166	.167	117.16	1160	20	57180
	4	4.500	4.072	.214	193.81	760	20	57187
	6	6.625	5.993	.316	422.31	360	20	57195
	8	8.625	7.805	.410	716.77	280	16	57199
	10**	10.750	9.728	.511	1113.20	160	16	57200
	12**	12.750	11.538	.606	1568.19	120	12	57201

** NON-STOCK ITEM

GASKET JOINT PIPE IS 20 FT. LAYING LENGTH ± 1" WITH INSERTION RING MARKED ON THE BEVELED SPIGOT END OF PIPE.

GASKET JOINT PIPE IS PRODUCED WITH AN INTEGRAL BELL END WITH A REINFORCED GASKET CONFORMING TO ASTM F477.

CRESLINE RECLAIMED WATER PIPE IS PURPLE IN COLOR.



CRESLINE - WEST, INC.

CORPORATE HEADQUARTERS: 600 CROSS POINTE BOULEVARD • EVANSVILLE, IN 47715 • TELEPHONE (812) 428-9300

PLANT: 3747 W. BUCKEYE ROAD • PHOENIX, AZ 85009 • TELEPHONE (602) 269-5161

www.cresline.com